

## TECHNICAL SHEET

Sir Safety System S.p.A. Single-member company

Wholly-owned subsidiary of Sir Holding Srl Via dei Fornaciai, 9 - Santa Maria degli Angeli 06081 Assisi - Perugia - Italy Tel.+39 075.8043737 (R.A.) - Fax +39 075.8048686 VAT Nr. IT 03359340548 Viale Europa 74 20090 Cusago Milano Tel. +39 02.90394575 (R.A.) Fax +39 02.90394441

	cc
export@sirsafety.com	QU
www.sirsafety.com	CERT
www.siisaiely.com	

COMPANY WITH QUALITY SYSTEM CERTIFIED BY DNV GL = ISO 9001 =



## Name: Glove Electro Class 2 Code: 75103A **Special Protection Gloves** Description Dielectric glove Class 2 - Insulation up to 20.000V. Length: 36 cm. Thickness: mm 2,3 in Natural Latex. Proof Test:20 kV. Whitstand Test: 17 kV. Supplied in a special polyethylene sealed case. The product is designed and manufactured to comply with the essential health and safety requirements of Directive 89/686/EEC. It is classified as PPE Cat. III. Category Colours Available Sizes 8-9-10-11 Ш Yellow Quantity/Carton Important Information Recommended for Make sure the garment is in good condition, Protection against contact with voltage-carrying undamaged and clean before use. Once you parts under voltage.

Storage and cleaning Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between 5-35° C. If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene, etc. Then wash with water at a temperature below 25° C and soap and dry thoroughly.