

Sir Safety System S.p.A. Single-member company
Wholly-owned subsidiary of Sir Holding Srl
Via dei Fornaciai, 9 - Santa Maria degli Angeli
06081 Assisi - Perugia - Italy
Tel.+39 075.8043737 (R.A.) - Fax +39 075.8048686

VAT Nr. IT 03359340548
Viale Europa 74
20090 Cusago Milano
Tel. +39 02.90394575 (R.A.)
Fax +39 02.90394441

export@sirsafety.com
www.sirsafety.com

COMPANY WITH
QUALITY SYSTEM
CERTIFIED BY DNV GL
= ISO 9001 =



Name: Glove Electro Class 3	Code: 75104A	Special Protection Gloves
------------------------------------	---------------------	----------------------------------


Description

Dielectric glove Class 3 - Insulation up to 30.000V.
Length: 36 cm.
Thickness: mm 2,9 in Natural Latex.

Supplied in a special polyethylene sealed case.

The product is designed and manufactured to comply with the essential health and safety requirements of Directive 89/686/EEC.
It is classified as PPE Cat. III.



Category III	Colours Yellow	Available Sizes 9-10-11
Quantity/Carton 1	Important Information We recommend six-monthly voltage test. Make sure the garment is in good condition, undamaged and clean before use. Once you become aware of a damage, you should immediately replace it.	Recommended for Protection against contact with voltage-carrying parts under voltage.
Dexterity	EC Standards EN 60903 CE  Acid, Oil, Ozone:R Resistant to very low temperatures:C	Storage and cleaning Store the gloves in their original sealed case, in a dry place far from the light, at a temperature between 5-35° C. If gloves become soiled with sticky substances or dyes, they shall be rubbed with suitable solvents, without brushes or abrasive paper. Do not use naphtha, gasoline, liquid paraffin, toluene, xylene, etc. Then wash with water at a temperature below 25° C and soap and dry thoroughly.